

TYPE TEST REPORT OF EQUIPMENTS

SI No	Equipment	Test Carried out	Date	Test Certificate No	No of Page	Laboratory	Remarks
1	25KVA DTR LTDist Board , 415V,60A	Short Circuit 10KA for 2 Sec	14.12.2017	SC172128	13	CPRI Bangaluru	Satisfactory
2	63KVA DTR LT Dist Board ,415V,160A	Short Circuit 10KA for 2 Sec	14.12.2017	SC172129	13	CPRI Bangaluru	Satisfactory
3	100KVA DTR LT Dist Board ,415V 170A	Short Circuit 20KA for 2 Sec	14.12.2017	SC172130	13	CPRI Bangaluru	Satisfactory
4	25KVA DTR LTDist Board , 415V,60A	Temp. Rise Test	24.11.2017	HRTL/112/NOV/2017	5	CPRI Bangaluru	Satisfactory
5	63KVA DTR LT Dist Board ,415V,160A	Temp. Rise Test	26.11.2017	HRTL/113/NOV/2017	5	CPRI Bangaluru	Satisfactory
6	100KVA DTR LT Dist Board ,415V 170A	Temp. Rise Test	28.11.2017	HRTL/115/NOV/2017	5	CPRI Bangaluru	Satisfactory
7	500KVA DTR LT Dist Board , 415V 800A	Temp. Rise Test	20.03.2019	CPRIBLRHRTL19T0026	6	CPRI Bangaluru	Satisfactory
8	500KVA DTR LT Dist Board , 415V 667A	Temp. Rise Test	20.03.2019	CPRIBLRHRTL19T0027	6	CPRI Bangaluru	Satisfactory
9	315KVA DTR LT Dist Board ,415V 530A	Temp. Rise Test	18.03.2019	CPRIBLRHRTL19T0024	6	CPRI Bangaluru	Satisfactory
10	250A AC Dist Board 415V 250A	Temp. Rise Test	19.03.2019	CPRIBLRHRTL19T0025	6	CPRI Bangaluru	Satisfactory
11	250KVA DTR LT Dist Board ,415V 333A	Temp. Rise Test	22.03.2019	CPRIBLRHRTL19T0028	6	CPRI Bangaluru	Satisfactory
12	315KVA DTR LT Dist Board ,415V 530A	Short Circuit 8KA for 2 Sec	26.03,2019	CPRIBLRHRTL19T0275	13	CPRI Bangaluru	Satisfactory
13	250A AC Dist Board 415V 250A	Short Circuit 20KA for 1 Sec	26.03.2019	CPRIBLRHRTL19T0276	13	CPRI Bangaluru	Satisfactory
14	200A AC Dist Board 415V 200A	Short Circuit 20KA for 1 Sec	26.03.2019	CPRIBLRHRTL19T0291	13	CPRI Bangaluru	Satisfactory
15	D C Dist Board	IP52	16.03.2019	CPRIBLREATD19T0137	6	CPRI Bangaluru	Satisfactory
16	AC Dist Board 200A	IP52	16.03.2019	CPRIBLREATD19T0138	6	CPRI Bangaluru	Satisfactory
17	500V 250A Fuse Base with Solid Link	Mechanical Operation, HV & LC	23.05.2018	CPRIBLRHRTL1819T0027	5	CPRI Bangaluru	Satisfactory
18	415V 6000A LT Panel	Short Circuit 50KA for 1 Sec	18.12.2017	SC172132	13	CPRI Bangaluru	Satisfactory
19	415V6000A Bus Duct	Short Circuit 50KA for 1 Sec	18.12.2017	SC172131	13	CPRI Bangaluru	Satisfactory
20	500V 250A Fuse Base with Solid Link	Short Circuit 4KA for 2 Sec	16.05.2018	CPRIBLRHRTL1819T0026	5	CPRI Bangaluru	Satisfactory
21	LT Metering Box 250KVA	Short Circuit 20KA for 2 Sec	23.03.2018	SC180310	13	CPRI Bangaluru	Satisfactory
22	440V 250A AC Fuse Base with Solid Link	Temp. Rise Test	07.05.2018	CPRIBLRHRTL1819T0008	4	CPRI Bangaluru	Satisfactory
23	60A 415V AC 25KVA LTCT Metering Box	Temp. Rise Test	29.11.2017	HRTL/117/Nov/2017	5	CPRI Bangaluru	Satisfactory
24	160A 415V AC 63KVA LTCT Metering Box	Temp. Rise Test	02.12.2017	HRTL/121/Nov/2017	5	CPRI Bangaluru	Satisfactory
25	160A 415V AC 63KVA LTCT Metering Box	Temp. Rise Test	30.11.2017	HRTL/120/Nov/2017	5	CPRI Bangaluru	Satisfactory
26	500KVA DTR LT Dist Board 800A	Short Circuit 20KA for 2 Sec	18.12.2017	SC172145	13	CPRI Bangaluru	Satisfactory
27	250KVA DTR LT Dist Board ,415V 400A	Short Circuit 20KA for 2 Sec	18.12.2017	SC172144	13	CPRI Bangaluru	Satisfactory
28	100KVA DTR LT Dist Board ,415V 170A	IP-55	27.12.2017	ERTL(E)/TES/S317/0017/12-17	5	ERTL(E) KOL	Satisfactory
29	LTCT Metering Box	IP-55	27.12.2017	ERTL(E)/TES/S317/0018/12-17	5	ERTL(E) KOL	Satisfactory
30	25KVA LT Dist Board	IP-55	27.12.2017	ERTL(E)/TES/S317/0015/12-17	5	ERTL(E) KOL	Satisfactory
31	500KVA LT Dist Board 800A	IP-33	18.03.2019	HRTL19RS0016	6	CPRI Bangaluru	Satisfactory
32	250KVA LT Dist Board 400A	IP-33	18.03.2019	HRTL19RS0017	6	CPRI Bangaluru	Satisfactory

TYPE TEST REPORT OF EQUIPMENTS

SI No	Equipment	Test Carried out	Date	Test Certificate No	No of Page	Laboratory	Remarks
33	315KVA DTR LT Dist Board ,415V 530A	IP-33	20.03.2019	HRTL19S0014	6	CPRI Bangaluru	Satisfactory
34	25KVA LT Dist Board	IP-33	20.03.2019	EATDIP19S0076	6	CPRI Bangaluru	Satisfactory
35	AC Dist Board 200A	IP-43	20.03.2019	EATDIP19S0077	6	CPRI Bangaluru	Satisfactory
36	D C Dist Board	IP-33	20.03.2019	EATDIP19S0078	6	CPRI Bangaluru	Satisfactory